

REVISIONS

NO.	DESCRIPTION	DATE

REINFORCED CONCRETE SLAB NOTES:

1. CONCRETE SHALL BE CLASS S WITH A MINIMUM 28 DAY COMPRESSIVE STRENGTH OF 3500 PSI.
2. REINFORCING STEEL SHALL BE AASHTO M31 OR M53, GRADE 60.
3. SLAB TO BE PLACED ON MINIMUM 6" OF CLASS 7 STONE OR APPROVED ALTERNATIVE.
4. CONTROL JOINTS TO BE SPACED NO GREATER THAN 15' APART IN ANY DIRECTION.
5. PRE-MOLD OR SAW CUT CONTROL JOINTS TO DEPTH EQUAL TO 1/4 OF THE THICKNESS OF THE SLAB (2.5" FOR A 10" SLAB).

STORM WATER POLLUTION PREVENTION REQUIREMENTS

1. INSTALL SILT FENCE DOWN GRADIENT OF ALL AREAS WHERE THE GROUND SURFACE IS DISTURBED.
2. INSTALL SILT FENCES AROUND THE OPENINGS OF CURB INLET BOXES, UPSTREAM ENDS OF PIPE, IN OUTLET DITCHES AND AS DIRECTED BY THE ENGINEER.
3. INSTALL ROCK CHECK DAMS AS DIRECTED BY THE ENGINEER.
4. INSTALL STABILIZED B-STONE ACCESS ROADS INTO THE PROJECT SITE AS DIRECTED BY THE ENGINEER AND ROUTE TRAFFIC LEAVING DISTURBED AREAS OF THE SITE OVER THE STABILIZED ENTRANCE ROADS.
5. PREVENT THE TRACKING OF MUD AND DIRT ONTO ADJACENT STREETS. IF ANY TRACKING OCCURS THE MATERIAL SHALL BE REMOVED FROM THE ROADWAY IMMEDIATELY.
6. KEEP HAUL ROADS WATERED TO PREVENT DUST FROM BLOWING DRIFTING ONTO NEARBY RESIDENCES.
7. MAINTAIN SILT FENCES, BALED HAY DIKES AND ROCK CHECK DAMS, RESTORING THE SEDIMENT CONTROL MEASURES AS REQUIRED AND REMOVING THE ACCUMULATION OF SEDIMENTS.

NOTES:

1. CITY OF CONWAY STANDARD DETAILS FOR ROADWAY AND DRAINAGE CONSTRUCTION ARE LOCATED ON THE TRANSPORTATION DEPARTMENT WEB PAGE. REFERENCE THIS FOR GENERAL NOTES AND CONSTRUCTION DETAILS. HARD COPY CAN BE PROVIDED.
2. ALL CONSTRUCTION & MATERIALS SHALL COMPLY WITH THE ARKANSAS HIGHWAY & TRANSPORTATION DEPARTMENT STANDARD SPECIFICATIONS FOR HIGHWAY CONSTRUCTION, CURRENT EDITION, UNLESS OTHERWISE NOTED.
3. NOTIFY THE TRANSPORTATION DEPARTMENT OF ANY FIELD CHANGES THAT MAY BE NECESSARY.

TOAD SUCK FERRY
CONCRETE SLAB

JOB NUMBER: 20-122
DRAWN BY: NTR
CHECKED BY: BFV3
DATE: 8/25/20
SCALE: N.T.S.

TOAD SUCK FERRY
CONCRETE SLAB

C1

